

Data Sheet | Item Number: 2007-8446

Adjacent jumper for switching lever; 6-way; insulated; orange

<https://www.wago.com/2007-8446>



Color: ■ orange



Electrical data

Rated current	30 A
---------------	------

Physical data

Width	47.2 mm / 1.858 inches
Depth	13 mm / 0.512 inches

Material data

Color	orange
Fire load	0.033 MJ
Weight	6 g

Commercial data	
Product Group	22 (TOPJOB S)
PU (SPU)	50 (10) pcs
Packaging type	Box
Country of origin	DE
GTIN	4050821484943
Customs tariff number	85366990990

Product Classification	
UNSPSC	39121421
eCl@ss 10.0	27-14-11-40
eCl@ss 9.0	27-14-11-40
ETIM 9.0	EC000489
ETIM 10.0	EC000489
ECCN	NO US CLASSIFICATION

Environmental Product Compliance	
RoHS Compliance Status	Compliant, No Exemption

Environmental requirements			
Environmental Testing		Environmental Testing	
Test specification: Railway applications – Rolling stock – Electronic equipment	DIN EN 50155 (VDE 0115-200):2022-06	Extended testing: Monitoring of contact faults and interruptions	Passed
Test procedure: Railway applications – Rolling stock equipment – Vibration and shock tests	DIN EN 61373 (VDE 0115-0106):2011-04	Extended testing: Voltage drop measurement before and after each axis	Passed
Spectrum/Mounting location	Service life test, Category 1, Class A/B	Vibration and shock stress for rolling stock equipment	Passed
Functional test with noise-like oscillations	Test passed according to Section 8 of the standard		
Frequency	f ₁ = 5 Hz to f ₂ = 150 Hz		
Acceleration	0.101g (highest test level used for all axes)		
Test duration per axis	10 min.		
Test directions	X, Y and Z axes		
Monitoring of contact faults and interruptions	Passed		
Voltage drop measurement before and after each axis	Passed		
Simulated service life test through increased levels of noise-like oscillations	Test passed according to Section 9 of the standard		
Frequency	f ₁ = 5 Hz to f ₂ = 150 Hz		
Acceleration	0.572g (highest test level used for all axes)		
Test duration per axis	5 h		
Test directions	X, Y and Z axes		
Extended testing: Monitoring of contact faults and interruptions	Passed		
Extended testing: Voltage drop measurement before and after each axis	Passed		
Shock test	Test passed according to Section 10 of the standard		
Shock pulse form	Half sine		
Acceleration	5g (highest test level used for all axes)		
Shock duration	30 ms		
Number of shocks (per axis)	3 pos. und 3 neg.		
Test directions	X, Y and Z axes		

Approval	Standard	Certificate Name
Railway WAGO GmbH & Co. KG	-	Railway Ready

Downloads

Environmental Product Compliance

Compliance Search

Environmental Product Compliance 2007-8446 

Documentation

Bid Text

2007-8446	19.02.2019	xml 2.53 KB	↓
2007-8446	28.04.2017	doc 23.00 KB	↓

CAD/CAE-Data

CAD data

2D/3D Models
2007-8446

CAE data

EPLAN Data Portal 2007-8446	
WSCAD Universe 2007-8446	
ZUKEN Portal 2007-8446	

Installation Notes

Commoning



Preparing shorting path for the current transformer circuits.



Insert insulated, touch-proof circuit jumpers into jumper slot.



Insert insulated, touch-proof circuit jumpers into jumper slot.

Subject to changes. Please also observe the further product documentation!

Current addresses can be found at: www.wago.com